



“শেখ হাসিনার উদ্যোগ, ঘরে ঘরে বিদ্যুৎ”

ASHUGANJ POWER STATION COMPANY LTD.
(An Enterprise of Bangladesh Power Development Board)

Ashuganj, Brahmanbaria-3402, Bangladesh

Phone: +88-08528-74044, Fax: +88-08528-74014,

E-mail: apsc1@apsc1.com, apsc1bd@yahoo.com, Website: www.apsc1.com

APSC1/100MWHFO/PD/Amendment/2018/ 04

Dated: 06/01/2018

Amendment-06

Subject: Procurement of design, manufacture, inspection, testing, delivery to the Site, installation, testing & commissioning, performance test and related civil and building works including two years warranty period of Ashuganj 100 MW HFO Power Plant Project on Turnkey basis.

Tender reference No.: APSC1/100MWHFO/PD/IFT/2017/01, dated: 23/11/2017

Sl. No.	Clause No./Page No.	Items/ Descriptions	Existing	Amended as
1	Page: 125, GC Clause-55.01, Volume 1 of 2	Bangladesh Customs and import duties, levies, VAT and Tax	The VAT and Taxes imposed on Clearing and Forwarding Agent (C & F Agent) by the port authority is contractor account. Employer (APSC1) will not bear this cost.	The VAT and Taxes imposed on Clearing and Forwarding Agent (C & F Agent) by the port authority and inland transportation including loading and unloading etc. specified in the Price Schedule-1 as per applicable rate are contractor's account. Employer (APSC1) will not bear this cost.
2	Page 56, Clause 5.1 (1) of Volume 2 of 2 (Part-A) and other relevant clauses	“ Generator Step-up Transformer”	The maximum continuous rating of the Transformer (at ONAN) shall meet at any tap a total output of the generators, as defined in Vol. 2 of 2 (Part-A) clause 4.1.2. Generator Rating, which is connected with the transformer shall be 120% (one hundred and twenty percent) of the corresponding MVA (pf=0.8) of the Guaranteed Net Generator output at Site condition of 35° C, 1.013 bar and 98% RH. The vector group of the Transformer shall be Ynd1.	The maximum continuous rating of the Transformer (at ONAF) shall meet at any tap a total output of the generators, as defined in Vol. 2 of 2 (Part-A) clause 4.1.2. Generator Rating, which is connected with the transformer shall be 120% (one hundred and twenty percent) of the corresponding MVA (pf=0.8) of the Guaranteed Net Generator output at Site condition of 35° C, 1.013 bar and 98% RH. The vector group of the Transformer shall be Ynd1.

All other terms and conditions of the Tender shall remain unchanged.


Md. Kamruzzaman Bhuyan

Project Director

Ashuganj 100 MW HFO Power Plant Project

APSC1, Ashuganj, Brahmanbaria-3402

Bangladesh.